

GCSD Highlights

- Would like to acknowledge District employee Anthony Trujillo for his 9 years of service.
- The District recently received a letter from one of our customers in regards to excellent customer service. The letter highlighted two District employees Pat Sommarstrom and Gene Pike and all Admin staff for outstanding customer service. The District strives for great customer service and these types of correspondences reflect the commitment we have at all staff levels.

Capital Projects

Coordinated closely with Moyle Excavation during the repair of Ferretti Rd Water and Sewer lines.

CCTV sewer line after installation and assisted with the 10" water line disinfection.



- Coordinated with District Engineer on Reservoir 1 bypass valve/vault replacement. Sent out request for bids.

Water

- Performed weekly checks and calibrations on all analyzers at 2G, BC, and AWS.
- Performed monthly UV calibrations at 2G and BC.
- Took weekly plant and distribution samples.
- Monitored Distribution Tank weekly.
- Worked/operated AWS (adjusting chemical pumps, calibrating monitoring equipment) and worked with STS on computer reporting issue.
- Submitted monthly Water Treatment Report and Conservation Report.
- Completed weekly checks on Tank 4 (Building, Pneumatic Tank, Pumps and MCC Cabinet) and Highlands Pump stations (Building, pumps and MCC Cabinet).
- Monthly lock offs due to nonpayment.
- Coordinated with Anderson Pump and Power services for Pump test on Big Creek Turbine due to loss of GPM. (Recommended by both companies to pull and repair bowl assemblies)
- Pulled wire and coordinated with Industrial Electric with the start up of Tank 2 Booster Pump Generator.
- Cleaned out all Valve Boxes in Unit 12 and completed Directional Flushing of water system.

Water Breaks

- Changed out curb stop on Elder Ln.
- Water break on Pleasant View Drive (1.25" Service Tube). Staff had to shut down street due to location of break. Samples were taken and sent to Aqua Lab. Results met all State Standards.
- Water break on Reid Circle 1" service line.

Wastewater:

- Took monthly reservoir samples and weekly plant samples.
- Chemical and Hydro flushed multiple gravity lines throughout the District.
- Submitted monthly Wastewater Report and No Spill report.
- Completed weekly (PMCS) Preventative Maintenance Checks and Services of all Lift Station.
- Cleaned Lift Station 1, 2, 3, 4, 5, 9, 10, 11, 12, 13, 14, 15 & 16. (PT, Floats and Wet well)
- Removed and installed new Motor for the STP Irrigation Pump.
- Completed Lift Station 15 Gravity Manhole inspections.
- Picked up Lift Station Pump #2 from Industrial Electric (pump tested OK). Reset pump and coordinated with Industrial Electric on VFD and main pump breaker inspection.
- Cleaned the STP Chlorine Generator.
- Inspected 19 of LS 1 gravity Manholes.
- Worked with District Engineer on Sanitary Sewer Management Plan (SSMP).

Maintenance

- Completed weekly Generator Checks.
- Coordinated with Barton Door on the installation of new roll up door for the amphitheater at the lower park.
- Coordinated with PH Electric on the Fire House Light repairs.



- Replaced Dump Truck air compressor governor, serviced Clutch/Brakes and replaced hydro booster on Truck 15.
- Repaired LS 15 Generator radiator hose, fuel lift pump on LS 3 generator and serviced LS 12 Generator.
- Road repair for the ballfield and Spray Field #3 road.
- Coordinated with Central California Generator with the repairs to 2G, Tank 2 and diagnosed LS 2 coolant problem.(Batteries, Cables, H-Board and Coolant Sensor)
- Coordinated with PH Electric on District Parking Lot Light Repairs dug and poured pole footings.

Call Outs

- 4 Sewer
- 2 Water